

- 26.40.050 - Fluoridation of water.

A.

The manager of the utility is authorized and directed to continue supplementing the fluoride content of the water supply, to maintain a level of not more than 1.3 parts per million.

B.

All techniques used to apply fluoride, including testing the water before and after the addition of fluoride, determining the fluoride content, and testing for purity of the fluoride chemicals, shall, in all respects, comply with the rules and standards set by the Alaska Department of Environmental Conservation, and the National Primary Drinking Water Regulations.

C.

The personnel who will make the necessary analyses and apply the fluoride will be state-certified water treatment operators.

(AO No. 90-12; AO No. 2004-99, § 1, 6-22-04)

1<sup>st</sup> Class  
Postage, 4X14"  
pages max

CLEAN WATER TEAM ANCHORAGE

Susan Kanen, Biochemist

9050 Rocky Cove Dr.

Fold 2x, tape, do not staple

Anchorage, Alaska 99507